



Dates Inspected:						Inspected by:

TS-0065

Fire Extinguisher

These instructions are to be used as a guide to help you maintain your home or office in a safe and efficient manner. They do not replace the requirements of the manufacturer. You should ALWAYS review your owner’s manual for additional preventive maintenance requirements.

This inspection is designed to keep your fire extinguisher accessible and charged.

Note: Every facility should have at least one fire extinguisher. Facilities that store ammunition, fireworks, and other flammables should have a fire extinguisher dedicated to the kitchen and others near the known flammables.

Places you may have fire extinguishers that need inspected include:

- Facilities
- Vehicles
- Motor homes
- Boats
- Airplanes
- Garage or shed

1. Locate your fire extinguisher(s) and make sure everyone in your facility knows where they are. Make sure all fire extinguishers are accessible in case of an emergency.
2. Check the gauge on each fire extinguisher to see if the extinguisher is charged properly.
3. Check the band that secures the pin to ensure it is present. If it is missing, consider having the extinguisher checked by a professional or replacing it.

Fire Safety Reminder:

- Remember to put a lid on grease fires.
- Develop a fire escape route for you and the occupants in the home
- Practice your fire escape route with occupants.

Take the time to do a thorough inspection. Ask if you have questions!