



If you have questions email: [www.toltekservices.com](http://www.toltekservices.com)  
[info@toltekservices.com](mailto:info@toltekservices.com)

<b>Dates Inspected:</b>						<b>Inspected by:</b>

**TS-0011**

**Water Softener**

*These instructions are to be used as a guide to help you maintain your home or office in a safe and efficient manner. They do not replace the requirements of the manufacturer. You should ALWAYS review your owner's manual for additional preventive maintenance requirements.*

This inspection is designed to increase operational efficiencies and save resources such as water and electricity.

1. Inspect water softener piping for leaks or corrosion.
2. Inspect the salt level in the brine tank. Fill if necessary.

Keeping the tank filled is important because most water softeners cannot detect a lack of salt and they will attempt to recycle even if there is no salt. This wastes water and electricity.

Take the time to do a thorough inspection. Ask if you have questions!